



Bay Metropolitan Transportation Authority
1510 N. Johnson St. • Bay City, Michigan 48708
Phone 989-894-2900 • Fax 989-894-2621
www.baymetro.com

Question & Answer

February 22, 2021

RFP 2021-02 Bus Wash System

There have been questions asked from Vendors about the project, below are the questions and answers.

Question Is a General Contractor's license required for the project?

The proposer is responsible for all Licensing and permits for the project, Bay Metro Transit's facility is within the city of Bay City Michigan and all permits fall under their jurisdiction.

The city of Bay City's Building Department can be reached at 989-894-8162 for inquires as to what will be needed for permits.

Question Can you confirm the volts and amps available for the bush wash and water recycling system?

Volts and Amps were determined to be 100 amps and 480 Volts by the electricians that were on site during the pre-bid meeting. (On site visit should be scheduled to confirm if there is additional access available if needed)

Question can you confirm the dimensions of the settling pit?

Concrete patch is 4'6" X 7'. Vendors may schedule a visit to verify actual pit size if needed

Question Can you confirm the size of the overflow to sanitary sewer?

6" trench drain from pit. Please see attached underground plumbing drawings.

A handwritten signature in black ink, appearing to read "Tom Dominowski". The signature is written in a cursive, flowing style.

Tom Dominowski
Purchasing Agent
tdominowski@baymetro.com
989-922-3710

